

**CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD  
COLORADO RIVER BASIN REGION**

STATEMENT OF BASIS  
APPLICATION FOR  
NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM (NPDES) PERMIT  
AND  
WASTE DISCHARGE REQUIREMENTS  
TO DISCHARGE TO STATE WATERS

Permittee Name:	Niland Sanitary District	Public Notice No.:	7-03-15
NPDES Permit Number:	CA0104451	Board Order No.:	R7-2003-0049
Mailing Address:	Niland Sanitary District P.O. Box 40 Niland, CA 92257		
Location:	125 West Alcott Street, Niland CA 92257		
Contact Person:	John Kemp		
Telephone:	(760) 359-0454		

I. Status of Permit

Niland, owner/operator (hereinafter referred to as the discharger), of the Niland Sanitary District Wastewater Treatment Plant (WWTP) submitted an application to update its Waste Discharge Requirements and to renew its permit to discharge wastewater under the National Pollutant Discharge Elimination System (NPDES). The application is for the wastewater treatment facility located at the address mentioned above.

II. Facility Description

The Niland Sanitary District owns and operates the wastewater collection, treatment and disposal system (hereinafter referred to as facility) and provides sewerage service to the City of Niland. The wastewater treatment plant, has a treatment capacity of 0.50 million gallons-per-day (MGD) and is located in Section 9, T11S, R14E, SBB&M. The permitted effluent discharge is 0.49 MGD.

The treatment system consists of a manual bar screen, three lined partial-mix aerated stabilization ponds connected in series, and a chlorination/dechlorination system. The total detention time in the basins is 20 days. The effluent is oxygenated by six – 7.5 horsepower aerators, which provide 1,890 pounds of oxygen per day.

The effluent from Pond No. 3 goes to a chlorine contact chamber with a normal contact time of 2 hours, where it is chlorinated with sodium hypochlorite. It is then dechlorinated by the addition of sodium metabisulfite.

III. Description of Discharge

**CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD  
COLORADO RIVER BASIN REGION**

The final effluent is discharged through Outfall 001 to Imperial Irrigation District's "R" Drain located in the SW ¼ of Section 9, T11S, R14E, SBB&M. The "R" Drain flows four miles and then discharges to the Salton Sea. The discharge consists of equivalent to secondary treated domestic wastewater.

**IV. Receiving Water**

The receiving water for Outfall 001 is Imperial Irrigation District's "R" Drain. The "R" Drain flows four miles and then discharges to the Salton Sea.

1. The designated beneficial uses of waters in the Imperial Valley Drains are:

- a. Fresh Water Replenishment of Salton Sea (FRSH)
- b. Water Contact Recreation (REC I)<sup>1,2</sup>
- c. Non-Contact Water Recreation (REC II)<sup>1</sup>
- d. Warm Water Habitat (WARM)
- e. Wildlife Habitat (WILD)
- f. Preservation of Rare, Threatened or Endangered Species (RARE)<sup>3</sup>

**V. Proposed Technology-Based Effluent Limitations**

Regulations promulgated in 40 CFR §125.3(a)(1) require technology-based effluent limits for municipal dischargers to be placed in NPDES permits based on Equivalent to Secondary Treatment Standards, equivalent to Secondary Treatment Standards, or Equivalent to Secondary Treatment Standards with State Alternative Limits for TSS

The Federal Water Pollution Control Act Amendments of 1972 (PL 92-500) establish the minimum performance requirements for POTWs [defined in Section 304(d)(1)]. Section 301(b)(1)(B) of that Act requires that such treatment works must, as a minimum, meet effluent limitations based on secondary treatment as defined by the Environmental Protection Agency (EPA) administrator.

Based on this statutory requirement, EPA developed secondary treatment regulations, which are specified in 40 CFR Part 133. These technology-based regulations apply to all municipal wastewater treatment plants and identify the minimum level of effluent quality attainable by secondary treatment in terms of biochemical oxygen demand (BOD<sub>5</sub>), SS and pH.

**a. Equivalent to Secondary Treatment Standards**

This facility meets the technology-based regulations for the minimum level of effluent quality attainable by equivalent to secondary treatment standards in terms of biochemical oxygen demand (BOD<sub>5</sub>), SS, and pH.

---

<sup>1</sup> Unauthorized Use.

<sup>2</sup> The only Rec 1 usage that is known to occur is from infrequent fishing.

<sup>3</sup> Rare, endangered, or threatened wildlife exists in or utilizes some of these waterway(s). If the RARE beneficial use may be affected by a water quality control decision, responsibility for substantiation of the existence of rare, endangered, or threatened species on a case-by-case basis is upon the California Department of Fish and Game on its own initiative and/or at the request of the Regional Board; and such substantiation must be provided within a reasonable time frame as approved by the Regional Board.

**CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD  
COLORADO RIVER BASIN REGION**

<u>Technology-Based Requirements for Municipal Dischargers Equivalent to Secondary Treatment (40 CFR Part 133)</u>			
<u>Constituents</u>	<u>Units</u>	<u>30-Day<sup>4</sup> Arithmetic Mean Discharge Rate</u>	<u>7-Day<sup>5</sup> Arithmetic Mean Discharge Rate</u>
20° C BOD <sub>5</sub> <sup>6</sup>	mg/L	45	65
TSS	mg/L	95	
pH	pH units	6 - 9	-----
Removal Efficiency for BOD	%	65	-----

Constituents

Basis for Limitations

Biochemical Oxygen Demand (BOD)

Discharges to waters that support aquatic life, that is dependent on oxygen. Organic matter in the discharge may consume oxygen as it breaks down.

Total Suspended Solids (TSS)

High levels of suspended solids can adversely impact aquatic habitat. Untreated or improperly treated wastewater can contain high amounts of suspended solids.

Hydrogen Ion (pH)

Hydrogen Ion (pH) is a measure of Hydrogen Ion concentration in the water. A range specified between 6 to 9 ensures suitability of biological life. This limitation has been adopted in the Basin Plan of the Region.

VI. Proposed Water Quality-Based Effluent Limitations

<sup>4</sup> 30 Day Mean- Arithmetic average of all samples collected during the calendar month

<sup>5</sup> 7 Day Mean- Arithmetic average of all samples collected during a calendar week (Sunday through Saturday)

<sup>6</sup> Biochemical Oxygen Demand

**CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD  
COLORADO RIVER BASIN REGION**

Effluent discharged from this facility could contain pollutants in sufficient quantities to affect receiving water quality. Pursuant to Section 13263, Article 4, Chapter 4 of the Porter Cologne Water Quality Control Act, the Regional Boards are required to issue Waste Discharge Requirements for discharges that could affect the quality of the State's waters. Furthermore, Federal Regulation 40 CFR 122.1 requires the issuance of NPDES permits for pollutants discharged from a point source to the waters of the United States. The draft discharge requirements contain specific discharge limitations for selected pollutants.

<u>Constituents</u>	<u>Basis for Limitations</u>
Total Dissolved Solids	High levels of TDS can adversely impact aquatic life. The TDS limit is from the Basin Plan of the Region.
Toxicity	Toxicity testing ensures that the effluent does not contain metals, chemicals, pesticides or other constituents in concentrations toxic to aquatic life.
<i>Escherichia Coli</i> (E. coli)	These limits are required by the Basin Plan for waters designated for water contact recreation (RECI) or noncontact water recreation (RECI).
Chlorine Residual	This limitation is based on the U.S. Environmental Protection Agency's – <u>Ambient Water Quality Criteria for Chlorine – 1984</u>

The U.S. Environmental Protection Agency published the adopted California Toxics Rule (CTR) (40 CFR §131.38). The CTR promulgates new criteria for both human health protection and protection of aquatic life. New numeric aquatic life criteria for 23 priority toxic pollutants and numeric human health criteria for 57 priority toxic pollutants are listed. In addition, the CTR contains a compliance schedule provision, which authorizes the State to issue schedules of compliance for new or revised NPDES permit limits based on the federal criteria when certain conditions are met.

The following final water quality based effluent limitations are based on monitoring results and using the California Toxic Rule and the Policy for Implementation of Toxics Standards for Inland Surface Waters, Enclosed Bays, and Estuaries of California (The calculations are shown in Attachment "A")

Copper	Average Monthly Effluent Limit (µg/L) = 2.39 Maximum Daily Effluent Limit (µg/L) = 4.80
Selenium	Average Monthly Effluent Limit (µg/L) = 4.09 Maximum Daily Effluent Limit (µg/L) = 8.21
Thallium	Average Monthly Effluent Limit (µg/L) = 6.3 Maximum Daily Effluent Limit (µg/L) = 12.6

The discharger is not able to consistently comply with the new effluent limitations for Copper, Selenium, and Thallium. Therefore, interim limits have been set as follows:

The governing Water Quality Objective (WQO) for copper is 3.1 ug/L, the saltwater aquatic life criteria contained in the CTR. As noted in Finding 26, above, copper has reasonable potential to exceed water quality objectives, and final Water Quality Based Effluent Limitations (WQBELs) are required. The WQBELs calculated pursuant to State Implementation Policy (SIP) procedures are 2.39 µg/L monthly

**CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD  
COLORADO RIVER BASIN REGION**

average and 4.80 µg/L daily maximum. The Discharger indicated in its May 12, 2003, Feasibility Study that it is infeasible to comply immediately with the WQBELs. Therefore, pursuant to the provisions of the SIP, an interim effluent limit for copper is required. The previous permit did not contain an effluent limit for copper, and it is not possible to statistically determine current plant performance based on four data points. Therefore, the interim effluent limit is the Maximum Effluent Concentration (MEC), 29 µg/L. This interim effluent limit is based on the best professional judgment of Regional Board staff.

The governing Water Quality Objective (WQO) for selenium is 5.0 ug/L, the freshwater aquatic life criteria contained in the CTR. As noted in Finding 26, above, selenium has reasonable potential to exceed water quality objectives, and final Water Quality Based Effluent Limitations (WQBELs) are required. The WQBELs calculated pursuant to State Implementation Policy (SIP) procedures are 4.09 µg/L monthly average and 8.22 µg/L daily maximum. The Discharger indicated in its May 12, 2003, Feasibility Study that it is infeasible to comply immediately with the WQBELs. Therefore, pursuant to the provisions of the SIP, an interim effluent limit for selenium is required. The previous permit did not contain an effluent limit for selenium, and it is not possible to statistically determine current plant performance based on two data points. Therefore, the interim effluent limit is the Maximum Effluent Concentration (MEC), 12 µg/L. This interim effluent limit is based on the best professional judgment of Regional Board staff.

The governing WQO for thallium is 6.3 ug/L, the human health criteria contained in the CTR. As noted in Finding 26, above, thallium has reasonable potential to exceed water quality objectives, and final WQBELs are required. The WQBELs calculated pursuant to SIP procedures are 6.30 µg/L monthly average and 12.6 µg/L daily maximum. The Discharger indicated in its May 12, 2003, Feasibility Study that it is infeasible to comply immediately with the WQBELs. Therefore, pursuant to the provisions of the SIP, an interim effluent limit for thallium is required. The previous permit did not contain an effluent limit for thallium, and it is not possible to statistically determine current plant performance based on a single data point. Therefore, the interim effluent limit is the MEC, 17 µg/L. This interim effluent limit is based on the best professional judgment of Regional Board staff.

**VII. Proposed Effluent Limitations**

Table 1, contained later in this Fact Sheet, summarizes the proposed effluent limitations for Outfall 001. Proposed effluent limitations are based on equivalent to secondary treatment standards, California Toxics Rule, and Colorado River Basin Plan Water Quality Standards.

**VIII. Monitoring Requirements**

Monitoring for those pollutants expected to be present in the Outfall OO1 will be required as shown on the proposed monitoring and reporting program and as required in the "*Policy for Implementation of Toxics Standards for Inland Surface Waters, Enclosed Bays, and Estuaries of California*" adopted March 2, 2000.

**IX. Information Sources**

While developing effluent limitations and receiving water limitations, monitoring requirements, and special conditions for the draft permit, the following information sources were used:

- (1) EPA NPDES Application Forms 1 and 2A dated February 14, 2002.
- (2) Code of Federal Regulations – Title 40
- (3) Water Quality Control Plan (Colorado River Basin – Region 7) as amended to date.
- (4) Regional Board files related to Niland Sanitary District WWTP NPDES permit CA0104451

**CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD  
COLORADO RIVER BASIN REGION**

- (5) Porter-Cologne Water Quality Control Act with additions and amendments effective January 1, 2000.
- (6) Policy for Implementation of Toxics Standards for Inland Surface Waters, Enclosed Bays, and Estuaries of California adopted March 2, 2000.
- (7) California Toxics Rule, published May 18, 2000 by U.S. EPA.
- (8) National Toxics Rule (NTR), adopted by U.S. EPA on February 5, 1993.

**X. Written Comments**

Interested parties and agencies are invited to submit written comments on the proposed Waste Discharge Requirements and the Regional Board's Executive Officer's proposed determinations. Comments should be submitted in writing not later than June 20, 2003 to:

Executive Officer  
California Regional Water Quality Control Board  
Colorado River Basin Region  
73-720 Fred Waring Drive, Suite 100  
Palm Desert, CA 92260

The application number shall appear on the first page of any submitted comments. All comments received by the above date will be considered in the formulation of the final determinations.

**XI. Public Hearing**

The Waste Discharge Requirements will be considered by the Regional Board at a public hearing to be held at the City of La Quinta City Council Chambers, 78495 Calle Tampico, La Quinta on June 25, 2003.

**XII. Waste Discharge Requirements Appeals**

Any person may petition the State Board to review the decision of the Regional Board regarding Waste Discharge Requirements. A petition must be made within 30 days of the Regional Board's hearing.

**XIII. Additional Information**

Persons wishing further information may write to the following address:

California Regional Water Quality Control Board  
Colorado River Basin Region  
73-720 Fred Waring Drive, Suite 100  
Palm Desert, CA 92260

or call the Regional Board at (760) 346-7491.

**CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD  
COLORADO RIVER BASIN REGION**

TABLE 1  
PROPOSED EFFLUENT AND RECEIVING WATER LIMITATIONS  
NPDES PERMIT NO. CA0104451  
BOARD ORDER NO. R7-2003-0049  
NILAND SANITARY DISTRICT WWTP

EFFLUENT LIMITATIONS

1. Representative samples of wastewater discharged to Imperial Irrigation Districts "R" Drain from the treatment systems shall not contain constituents in excess of the limits indicated below. Each treatment system discharging to Imperial Irrigation Districts "R" Drain shall be monitored separately at locations which are acceptable by the Regional Board's Executive Officer or his designee:

<u>Constituent</u>	<u>Unit</u>	<u>30-Day Arithmetic Mean Discharge Rate<sup>7</sup></u>	<u>7-Day Arithmetic Mean Discharge Rate<sup>8</sup></u>
20° C BOD <sub>5</sub> <sup>9</sup>	mg/L <sup>10</sup>	45	65
	lb/day <sup>11</sup>	188 <sup>12</sup>	271
Total Suspended Solids	mg/L	95	
	lb/day	396	

2. The 30-day monthly average percent removal of the pollutant parameter BOD<sub>5</sub> shall not be less than 65 percent.
3. The hydrogen ion (pH) of the effluent shall be maintained within the limits of 6.0 to 9.0.
4. Wastewater effluent discharged to "R" Drain shall not have a Escherichia coli (E. coli) concentration in excess of a log mean of Most Probable Number (MPN) of 126 MPN per 100 milliliters (based on a minimum of not less than five samples for any 30-day period) nor shall any sample exceed 400 MPN per 100 milliliters. The compliance point for this effluent limitation shall be at a location acceptable to the Regional Board's Executive Officer or his designee.
5. Wastewater discharged to "R" Drain shall not contain a total chlorine residual greater than 0.02 mg/L as an instantaneous maximum and 0.01 mg/L as a monthly average. Compliance for this effluent limitation shall be at end of pipe prior to discharge into "R" Drain.
6. The discharge of wastewater shall not cause concentration of total dissolved solids (TDS) in surface water to exceed an annual average of 4,000 mg/L or a maximum daily of 4,500 mg/L.
7. There shall be no acute or chronic toxicity in the treatment plant effluent nor shall the treatment plant effluent cause any acute or chronic toxicity in the receiving water. All waters shall be maintained free of toxic substances in concentrations which are toxic to, or which produce detrimental physiological responses in human, plant, animal, or indigenous aquatic life.

<sup>7</sup> 30 Day Mean- Monthly arithmetic mean sample concentration

<sup>8</sup> 7 Day Mean- Weekly arithmetic mean samples concentration

<sup>9</sup> BOD<sub>5</sub> - Biochemical Oxygen Demand

<sup>10</sup> mg/L - milligrams per Liter

<sup>11</sup> lbs/day - pounds per day

<sup>12</sup> Based on a design treatment capacity of 0.5 MGD

**CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD  
COLORADO RIVER BASIN REGION**

Compliance with this objective will be determined by use of indicator organisms, analyses of species diversity, population density, growth anomalies, or bioassays of appropriate duration or other appropriate methods specified by the Regional Board.

8. Wastewater discharged to the “R” Drain shall not exceed these effluent limits. These limits are calculated based on monitoring results and using the California Toxic Rule and the Policy for Implementation of Toxics Standards for Inland Surface Waters, Enclosed Bays and Estuaries of California for water quality based effluent limits:

Constituents	Unit	Date Effluent Limit Becomes Effective	Average Monthly Effluent Limit	Maximum Daily Effluent Limit
Copper (interim)	µg/L	July 5, 2003	29.0	29.0
Copper (final)	µg/L	June 25, 2008	2.39	4.80
Selenium (interim)	µg/L	July 5, 2003	12.0	12.0
Selenium (final)	µg/L	June 25, 2008	4.09	8.22
Thallium (interim)	µg/L	July 5, 2003	17.0	17.0
Thallium (final)	µg/L	June 25, 2008	6.30	12.6

**RECEIVING WATER LIMITATIONS**

1. Receiving water limitations are based upon water quality objectives contained in the Basin Plan. As such, they are a required part of this permit. The discharge shall not cause the following in the “R” Drain:
  - a. Depress the concentration of dissolved oxygen to fall below 5.0 mg/L. When dissolved oxygen in the receiving water is already below 5.0 mg/L, the discharge shall not cause any further depression.
  - b. The presence of oil, grease, floating material (liquids, solids, foam and scum) or suspended material in amounts that create a nuisance or adversely affect beneficial uses.
  - c. Result in the deposition of pesticides or combination of pesticides to be detected in concentrations that adversely affect beneficial uses.
  - d. Aesthetically undesirable discoloration in the receiving water.
  - e. A significant increase in fungi, slime, or other objectionable growth.
  - f. Increase turbidity that results in affecting beneficial uses.
  - g. The normal ambient pH to fall below 6.0 or exceed 9.0 units.
  - h. Impact the receiving water temperature, resulting in adversely affecting beneficial uses.
  - i. Result in the deposition of material that causes nuisance or adversely affects beneficial uses.

**CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD  
COLORADO RIVER BASIN REGION**

- j. The chemical constituents to exceed concentrations that adversely affect beneficial uses or create nuisance.
  - k. Toxic pollutants to be present in the water column, sediments or biota in concentrations that adversely affect beneficial uses or that produce detrimental physiological responses in human, plant, animal, or aquatic life.
  - l. Taste or odor-producing substances to impart undesirable tastes or odors to fish flesh or other edible products of aquatic origin or to cause or otherwise adversely affect beneficial uses.
2. This discharge shall not cause a violation of any applicable water quality standard for receiving waters adopted by the Regional Board or the State Water Resources Control Board as required by the Federal Clean Water Act and regulations adopted thereunder. If more stringent applicable water quality standards are promulgated or approved pursuant to Section 303 of the Federal Water Pollution Control Act or amendments thereto, the Regional Board will revise and modify this Permit in accordance with such more stringent standards.